



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 4080 Series 05 Clad Ascent Outswing Patio Door Sidelite
PRODUCT TYPE: Aluminum Clad Sidelite / Fixed Door**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	FD-C50 1270 x 2438 (50 x 96) SLT-C50 1270 x 2438 (50 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG50 1270 x 2438 (50 x 96)-FD Class CW-PG50 1270 x 2438 (50 x 96)-SLT
Design Pressure	2400 Pa (50.0 psf)
Air Infiltration	0.51 L/s/m ² (0.10 cfm/ft ²)
Water Penetration Resistance Test Pressure	360 Pa (7.50 psf)
Uniform Load Structural Test Pressure	±3600 Pa (±75.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 11/23/09

Reference must be made to Report No. 96408.01-201-44, dated 07/30/10 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com