



**AAMA/WDMA/CSA  
TEST REPORT**

**Rendered to:**

**EAGLE WINDOW & DOOR, INC.**

**SERIES/MODEL: Series 05 Clad Ascent Outswing French Door SP1 Vent**

**PRODUCT TYPE: Aluminum Clad Wood Hinged Glass Double Door (XX)**

<b>Title</b>	<b>Summary of Results</b>
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C40 2007 x 3031 (79 x 119)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG40 2007 x 3031 (79 x 119)-SHD
Design Pressure	1920 Pa (40.0 psf)
Operating Force	62 N (14.0 lbf)
Air Infiltration	0.25 L/s/m <sup>2</sup> (0.05 cfm/ft <sup>2</sup> )
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
Uniform Load Structural Test Pressure	±2880 Pa (±60.0 psf)
Forced Entry Resistance	Pass

**Test Completion Date:** 06/03/10

Reference must be made to Report No. A1227.01-201-44, dated 07/12/10 for complete test specimen description and data.