



**AAMA/WDMA/CSA  
TEST REPORT**

Rendered to:

**EAGLE WINDOW AND DOOR**

**SERIES/MODEL: 3080 Series 05 Clad Outswing French Door SP1 with Harbor Master Mono Muller to a 3080 Series 05 Clad Outswing French Door Sidelite SP1 with Harbor Master Mono**

**PRODUCT TYPE: Aluminum Clad Outswing Hinged Glass Door with Impact Glazing Muller to an Aluminum Clad Sidelite/Fixed Door**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C60 1905 x 2421 (75 x 95) FD-C60 1905 x 2421 (75 x 95) SLT-C60 1905 x 2421 (75 x 95)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG60 1905 x 2421 (75 x 95)-SHD Class CW-PG60 1905 x 2421 (75 x 95)-FD Class CW-PG60 1905 x 2421 (75 x 95)-SLT
Design Pressure	2880 Pa (60.0 psf)
Negative Design Pressure	3600 Pa (75.0 psf)
Air Infiltration	<0.05 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
Uniform Load Structural Test Pressure	+4320, -5400 Pa (+90.0, -112.5 psf)
Forced Entry Resistance	Grade 10

**Test Completion Date:** 01/19/10

Reference must be made to Report No. 95123.02-201-18, dated 01/19/10 for complete test specimen description and data.