



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW AND DOOR, INC.

**SERIES/MODEL: Series 05 Clad Ascent
Outswing French Door Sidelite
PRODUCT TYPE: Aluminum Clad Wood
Fixed Door/Sidelite (O)**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG80 1016 x 2421 (40 x 95)-FD Class CW-PG80 1016 x 2421 (40 x 95)-SLT
AAMA/WDMA/CSA 101/I.S.2/A440-05	FD-C80 1016 x 2421 (40 x 95) SLT-C80 1016 x 2421 (40 x 95)
Design Pressure	3840 Pa (80.0 psf)
Air Infiltration	0.20 L/s/m ² (0.04 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level	Fixed
Water Penetration Resistance Test Pressure	580 Pa (12.0 psf)
Uniform Load Structural Test Pressure	±5760 Pa (±120.0 psf)
Forced Entry Resistance	Grade 40

Test Completion Date: 06/22/09

Reference must be made to Report No. 92651.01-201-44, dated 07/13/09 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com