



**AAMA/WDMA/CSA 101/I.S.2/A440-05
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 4020 Double Hung Transom
with Monolithic Impact Glazing
PRODUCT TYPE: Aluminum Clad Fixed Wood Window
with Monolithic Impact Glazing**

| Title | Summary of Results |
|--|---|
| Primary Product Designator | FW-R55 1219 x 610 (48 x 24) |
| Design Pressure | 2640 Pa (55.0 psf) |
| Negative Design Pressure | 3120 Pa (65.0 psf) |
| Air Infiltration | <0.05 L/s/m ² (<0.01 cfm/ft ²) |
| Water Penetration Resistance Test Pressure | 400 Pa (8.25 psf) |
| Uniform Load Structural Test Pressure | +3960, -4680 Pa (+82.5, -97.5 psf) |
| Forced Entry Resistance | Grade 10 |

Test Completion Date: 05/29/07

Reference must be made to Report No. 72964.01-201-44, dated 07/10/07 for complete test specimen description and data.