



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

SERIES/MODEL: Series 05 Clad Ascent Outswing French Door SP1R2 Vent

PRODUCT TYPE: Aluminum Clad Wood Hinged Glass Single Door (X)

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C60 978 x 2421 (38 x 95)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG60 978 x 2421 (38 x 95)-SHD
Design Pressure	2880 Pa (60.0 psf)
Operating Force	89 N (20.0 lbf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
Uniform Load Structural Test Pressure	±4320 Pa (±90.0 psf)
Forced Entry Resistance	Pass

Test Completion Date: 06/03/10

Reference must be made to Report No. A1230.01-201-44, dated 07/12/10 for complete test specimen description and data.