



**AAMA/WDMA/CSA 101/I.S.2/A440-05
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR COMPANY

**SERIES/MODEL: Series 01 Axiom Clad One-Piece Casement Fixed 6060
PRODUCT TYPE: Aluminum Clad Fixed Wood Window**

Title	Summary of Results
Primary Product Designator	FW-C80 1829 x 1829 (72 x 72)
Design Pressure	3840 Pa (80.0 psf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	580 Pa (12.0 psf)
Uniform Load Structural Test Pressure	+5760 Pa (+120.0 psf)
Forced Entry Resistance	Grade 40

Test Completion Date: 09/13/07

Reference must be made to Report No. 75733.01-201-44, dated 05/02/08 for complete test specimen description and data.