



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

SERIES/MODEL: 6-7 x 8-0 Series 05 Clad Ascent Inswing Post Door
PRODUCT TYPE: Aluminum Clad In-Swing Double Door (XO-center hinged)

Title	Summary of Results
101/I.S.2.NAFS-02	HGD-C45 2007 x 2438 (79 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C45 2007 x 2438 (79 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	CW-PG45-SHD 2007 x 2438 (79 x 96)
Design Pressure	2160 Pa (45.0 psf)
Air Infiltration	0.10 L/s/m ² (0.02 cfm/ft ²)
Water Penetration Resistance Test Pressure	330 Pa (6.75 psf)
Uniform Load Structural Test Pressure	±3240 Pa (±67.5 psf)
Forced Entry Resistance	Pass

Test Completion Date: 06/29/08

Reference must be made to Report No. 82746.01-201-44 dated 07/08/08 for complete test specimen description and data.