



Architectural Testing

**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

SERIES/MODEL: 6-7 x 8-5 5/16 Series 05 Clad Ascent Outswing French Door

PRODUCT TYPE: Aluminum Clad Outswing French Double Door

Title	Summary of Results
101/I.S.2.NAFS-02	HGD-C40 2007 x 2573 (79 x 101)
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C40 2007 x 2573 (79 x 101)
AAMA/WDMA/CSA 101/I.S.2/A440-08	LC-PG40-SHD 2007 x 2573 (79 x 101)
Design Pressure	1920 Pa (40.0 psf)
Air Infiltration	0.25 L/s/m ² (0.05 cfm/ft ²)
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
Uniform Load Structural Test Pressure	±2880 Pa (±60.0 psf)
Forced Entry Resistance	Pass

Test Completion Date: 06/30/08

Reference must be made to Report No. 82756.01-201-44 dated 07/09/08 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com