



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW AND DOOR, INC.

**SERIES/MODEL: Series 05 Clad Ascent
Outswing French Double Door with Handicap Sill
PRODUCT TYPE: Aluminum Clad Wood
Side-Hinged Door with Handicap Sill (XX)**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 2007 x 2410 (79 x 94) LW SHD
AAMA/WDMA/CSA 101/I.S.2/A440-05	LW SHD-LC50 2007 x 2410 (79 x 94)
Design Pressure	2400 Pa (50.0 psf)
Air Infiltration	0.15 L/s/m ² (0.03 cfm/ft ²)
Water Penetration Resistance Test Pressure	0 Pa (0 psf)
Uniform Load Structural Test Pressure	±3600 Pa (±75.0 psf)
Forced Entry Resistance	Pass

Test Completion Date: 07/08/09

Reference must be made to Report No. 91690.01-201-44, dated 07/10/09 for complete test specimen description and data.