



**AAMA/WDMA/CSA TEST REPORT**

**Rendered to:**

**EAGLE WINDOW & DOOR, INC.**

**SERIES/MODEL: 5080 Series 93 Clad Auxiliary Fixed**

**PRODUCT TYPE: Aluminum Clad Fixed Window**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 101/I.S.2/NAFS-02	Class CW-PG70: Size Tested 1524 x 2438 (60 x 96)-Type FW FW-C70 1524 x 2438 (60 x 96) F-C70 1524 x 2438 (60 x 96)
Design Pressure	3360 Pa (70.18 psf)
Negative Design Pressure	3840 Pa (80.20 psf)
Air Infiltration	<0.05 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Canadian Air Infiltration/Exfiltration Level	A3
Water Penetration Resistance Test Pressure	580 Pa (12.11 psf)
Uniform Load Structural Test Pressure	±5040 Pa (±105.26 psf)
Forced Entry Resistance	Grade 10

**Test Completion Date:** 02/08/09

Reference must be made to Report No. 87727.03-602-18, dated 03/20/09 for complete test specimen description and data.