



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**PRODUCT TYPE: 6780 Ascent Clad In-Swing Radius Double Door
SERIES/MODEL: Aluminum Clad Hinged Glass Door (XX)**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-LC40 2007 x 2438* (79 x 96*)
AAMA/WDMA/CSA 101/I.S.2/A440-08	LC-PG40-SHD 2007 x 2438* (79 x 96*)
ANSI/AAMA/WDMA 101/I.S.2-97	HGD-LC40 (79 x 96*)
Design Pressure*	1920 Pa (40.10 psf)
Operating Force (in motion)	31 N (7 lbf)
Air Infiltration	0.15 L/s/m ² (0.03 cfm/ft ²)
Canadian Air Infiltration/Exfiltration Level*	A3
Water Penetration Resistance Test Pressure*	290 Pa (6.06 psf)
Uniform Load Structural Test Pressure	±2880 Pa (60.15 psf)
Forced Entry Resistance	Pass

*-Optional Secondary Designators

Test Completion Date: 12/20/06

Reference must be made to Architectural Testing, Inc. Report No. 69351.02-602-44, dated 11/26/08 for complete test specimen description and data.

5906 Saxon Avenue
Schofield, WI 54476
phone: 715-241-8624
fax: 715-241-8425
www.archtest.com