



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOWS & DOOR, INC.

**SERIES/MODEL: 2080 Series 05 Clad Ascent Inswing French Door
Venting Sidelight with Standard IG
PRODUCT TYPE: Aluminum Clad Wood Venting Sidelight**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SLT-CW45 622 x 2438 (24 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	CW-PG45 622 x 2438 (24 x 96)-SLT
Design Pressure	2160 Pa (45.0 psf)
Negative Design Pressure	2400 Pa (50.0 psf)
Air Infiltration	0.36 L/s/m ² (0.07 cfm/ft ²)
Canadian Air Exfiltration	A3
Water Penetration Resistance Test Pressure	330 Pa (6.75 psf)
Uniform Load Structural Test Pressure	+3240, -3600 Pa (+67.5, -75.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 04/30/09

Reference must be made to Report No. 90245.01-201-44, dated 04/30/09 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com