



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

SERIES/MODEL: 16080 Clad Bi-Parting Patio Door

PRODUCT TYPE: Aluminum Clad Wood Bi-Parting Sliding Glass Door (OXXO)

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SD-LC25 4832 x 2438 (190 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG25 4832 x 2438 (190 x 96)-SD
Design Pressure	1200 Pa (25.0 psf)
Operating Force (in motion)	36 N (8.0 lbf)
Air Infiltration	0.25 L/s/m ² (0.05 cfm/ft ²)
Water Penetration Resistance Test Pressure	220 Pa (4.50 psf)
Uniform Load Structural Test Pressure	±1800 Pa (±37.5 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 12/11/09

Reference must be made to Report No. 96806.01-201-44, dated 02/02/10 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com