



**AAMA/WDMA/CSA  
TEST REPORT**

**Rendered to:**

**EAGLE WINDOWS AND DOORS**

**SERIES/MODEL: 3080 Series 05 Clad Outswing French Door SP1 with Harbor Master IG  
Mulled to a 3080 Series 05 Clad Outswing French Door Sidelite SL1 with Harbor Master IG**

**PRODUCT TYPE: Aluminum Clad Outswing Hinged Glass Door with Impact Glazing  
Mulled to an Aluminum Clad Sidelite/Fixed Door**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C65 1905 x 2421 (75 x 95) FD-C65 1905 x 2421 (75 x 95) SLT-C65 1905 x 2421 (75 x 95)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG65 1905 x 2421 (75 x 95)-SHD Class CW-PG65 1905 x 2421 (75 x 95)-FD Class CW-PG65 1905 x 2421 (75 x 95)-SLT
Design Pressure	3120 Pa (65.0 psf)
Air Infiltration	0.05 L/s/m <sup>2</sup> (0.01 cfm/ft <sup>2</sup> )
Water Penetration Resistance Test Pressure	470 Pa (9.75 psf)
Uniform Load Structural Test Pressure	±4680 Pa (±97.5 psf)
Forced Entry Resistance	Grade 10

**Test Completion Date:** 01/19/10

Reference must be made to Report No. 95121.01-201-44, dated 01/19/10 for complete test specimen description and data.