



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

**SERIES/MODEL: 8080 Series 05 Clad Ascent Sliding Patio Door
PRODUCT TYPE: Aluminum Clad Sliding Glass Door**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SD-LC30 2432 x 2438 (95 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG30 2432 x 2438 (95 x 96)-SD
Design Pressure	1440 Pa (30.0 psf)
Operating Force (in motion)	32 N (7.3 lbf)
Air Infiltration	0.66 L/s/m ² (0.13 cfm/ft ²)
Water Penetration Resistance Test Pressure	290 Pa (6.0 psf)
Uniform Load Structural Test Pressure	±2160 Pa (±45.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 11/24/09

Reference must be made to Report No. 96407.01-201-44, dated 07/30/10 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com