



Architectural Testing

**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW & DOOR, INC.

SERIES/MODEL: 8080 Series 05 Clad Ascent French Sliding Door SP1 with Harbor Master Mono Muller to a 4080 Series 05 Clad Ascent French Sliding Door Sidelite SL1 with Harbor Master Mono

PRODUCT TYPE: Aluminum Clad Sliding Glass Door with Impact Glazing Muller to an Aluminum Clad Sidelite/Fixed Door with Impact Glazing

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	SD-C60 2432 x 2438 (95 x 96) FD-C60 1270 x 2438 (50 x 96) SLT-C60 1270 x 2438 (50 x 96)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG60 2432 x 2438 (95 x 96)-SD Class CW-PG60 1270 x 2438 (50 x 96)-FD Class CW-PG60 1270 x 2438 (50 x 96)-SLT
Design Pressure	2880 Pa (60.0 psf)
Operating Force (in motion)	40 N (9.0 lbf)
Air Infiltration	0.61 L/s/m ² (0.12 cfm/ft ²)
Water Penetration Resistance Test Pressure	440 Pa (9.0 psf)
Uniform Load Structural Test Pressure	±4320 Pa (±90.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 03/26/10

Reference must be made to Report No. 98173.03-201-18, dated 08/23/10 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com