



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

EAGLE WINDOW AND DOOR, INC.

**SERIES/MODEL: Series 05 Clad Ascent
Outswing French Single Door**

**PRODUCT TYPE: Aluminum Clad Wood
Side-Hinged Door (X)**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG60 1016 x 2421 (40 x 95)-SHD
AAMA/WDMA/CSA 101/I.S.2/A440-05	SHD-C60 1016 x 2421 (40 x 95)
Design Pressure	2880 Pa (60.0 psf)
Air Infiltration	0.05 L/s/m ² (0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	440 Pa (9.00 psf)
Uniform Load Structural Test Pressure	±4320 Pa (±90.0 psf)
Forced Entry Resistance	Pass

Test Completion Date: 07/08/09

Reference must be made to Report No. 91693.01-201-44, dated 07/13/09 for complete test specimen description and data.

849 Western Avenue North
St. Paul, MN 55117
phone: 651-636-3835
fax: 651-636-3843
www.archtest.com